


Permit Reference Number : EPR / TP3836CT

Operator : Viridor

Installation: Beddington

Form Number: AIR 4 / 23/07/13 [A2]

Reporting of Continuously Monitored Emissions to Air for CO mg/m3 at Emission Point A2 For the month of August 2019



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
	Monthly maximum	770	Maximum Half-hourly average	8	6	7	19	6	13	8	93	15	20	15	5	266	6	10	11	8	382	29	6	11	7	9	19	770	268	36	12	5	217	117
	Monthly mean	5	Mean Half-hourly average	2	3	3	3	3	4	3	7	4	4	3	3	9	3	3	3	3	11	4	4	3	4	4	4	21	8	4	3	3	10	8
	Monthly minimum	0	Minimum Half-hourly average	0	0	0	0	1	0	0	0	0	0	0	0	0	0	2	1	1	1	1	2	2	1	2	2	0	0	2	1	1	2	0
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	7	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	2	1	0	0	0	1
Daily average			Daily average ELV	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50
	Monthly maximum	21	Daily average	2	3	3	3	3	4	3	7	4	4	3	3	9	3	3	3	3	11	4	4	3	4	4	4	21	8	4	3	3	10	8
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed: *[Signature]*

Date: 02.09.2019

(Authorised to sign as a representative of the Operator)