


Permit Reference Number : EPR / TP3836CT

Operator : Viridor

Installation: Beddington

Form Number: AIR 4 / 23/07/13 [A1]

Reporting of Continuously Monitored Emissions to Air for CO mg/m3 at Emission Point A1 For the month of June 2019



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
	Monthly maximum	134	Maximum Half-hourly average	4	3	7	4	5	11	12	6	4	64	74	111	6	43	12	7	98	50	38	Off	9	11	25	134	10	1	11	3	16	4	
	Monthly mean	4	Mean Half-hourly average	2	2	2	2	3	2	3	3	1	4	7	5	2	4	3	2	4	4	4	Off	2	2	4	45	3	0	0	1	2	2	
	Monthly minimum	0	Minimum Half-hourly average	0	0	0	1	1	1	2	1	0	0	1	0	0	1	1	0	0	0	0	Off	0	0	0	0	0	0	0	0	1	1	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of exceedances	3	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	Off	0	0	0	2	0	0	0	0	0	0	0
Daily average			Daily average ELV	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	
	Monthly maximum	45	Daily average	2	2	2	2	3	2	3	3	1	4	7	5	2	4	3	2	4	4	4	Off	2	2	4	45	3	0	0	1	2	2	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y		
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed.....
(Authorised to sign as a representative of the Operator)

Date.....06/07/2019