


Permit Reference Number : EPR / TP3836CT

Operator : Viridor

Installation: Beddington

Form Number: AIR 4 / 23/07/13 [A2]

Reporting of Continuously Monitored Emissions to Air for CO mg/m3 at Emission Point A2 For the month of March 2019



Monthly summary			Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
	Monthly maximum	547	Maximum Half-hourly average	9	4	5	9	6	7	10	7	6	8	16	8	8	8	7	6	8	3	5	5	5	6	5	5	547	75	5	44	8	33	6
	Monthly mean	4	Mean Half-hourly average	4	3	3	4	4	4	5	5	4	3	4	5	4	5	4	4	3	2	3	3	2	3	2	3	15	4	2	3	3	4	3
	Monthly minimum	0	Minimum Half-hourly average	2	2	2	2	1	3	1	3	1	2	2	3	2	3	1	2	0	1	2	2	1	1	1	1	1	0	0	0	1	1	0
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	1	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0
Daily average			Daily average ELV	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50
	Monthly maximum	15	Daily average	4	3	3	4	4	4	5	5	4	3	4	5	4	5	4	4	3	2	3	3	2	3	2	3	15	4	2	3	3	4	3
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed: *B. M. C.*

Date: 02.04.2019

(Authorised to sign as a representative of the Operator)