


Permit Reference Number : EPR / TP3836CT

Operator : Viridor

Installation: Beddington

Form Number: AIR 4 / 23/07/13 [A1]

Reporting of Continuously Monitored Emissions to Air for CO mg/m3 at Emission Point A1 For the month of November 2019



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100	100
	Monthly maximum	134	Maximum Half-hourly average	6	9	109	7	Off	Off	Off	Off	Off	Off	15	134	4	9	9	8	10	7	116	17	5	16	7	4	7	18	16	19	6	6	
	Monthly mean	4	Mean Half-hourly average	4	5	7	4	Off	Off	Off	Off	Off	Off	15	9	2	3	4	4	3	3	7	4	3	4	3	2	3	4	4	4	3	3	
	Monthly minimum	0	Minimum Half-hourly average	2	3	2	1	Off	Off	Off	Off	Off	Off	15	1	0	0	2	2	0	0	2	2	1	2	2	1	1	2	2	0	2	1	
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	3	No of exceedances of ELV	0	0	1	0	Off	Off	Off	Off	Off	Off	0	1	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0
Daily average			Daily average ELV	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50
	Monthly maximum	7	Daily average	4	5	7	N/A	Off	Off	Off	Off	Off	Off	N/A	N/A	2	3	4	4	3	3	7	4	3	4	3	2	3	4	4	4	3	3	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed.....

Date..... 04.12.2019

(Authorised to sign as a representative of the Operator)