


Permit Reference Number : EPR / TP3836CT

Operator : Viridor

Installation: Beddington

Form Number: AIR 5 / 23/07/13 [A1]

Reporting of Continuously Monitored Emissions to Air for SO₂ mg/m³ at Emission Point A1 For the month of February 2020



Monthly summary			Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200	200		
	Monthly maximum	224	Maximum Half-hourly average	9	8	15	5	8	72	80	17	9	58	23	27	72	56	41	45	62	103	50	50	21	56	81	56	192	187	58	224	11		
	Monthly mean	13	Mean Half-hourly average	4	4	4	3	3	13	6	5	4	7	5	7	10	16	19	26	17	28	21	12	6	14	26	23	27	28	22	22	5		
	Monthly minimum	1	Minimum Half-hourly average	3	3	3	2	2	2	1	3	3	3	3	2	3	4	4	11	4	4	4	4	4	4	7	7	6	5	5	4	4		
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	Sum of exceedances	1	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0		
Daily average			Daily average ELV	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50		
	Monthly maximum	28	Daily average	4	4	4	3	3	13	6	5	4	7	5	7	N/A	16	19	26	17	28	21	12	6	14	26	23	27	28	22	22	5		
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y		
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N		

Signed: *[Signature]*

Date: *04.03.2020*

(Authorised to sign as a representative of the Operator)