


Permit Reference Number : EPR / TP3836CT

Operator : Viridor

Installation: Beddington

Form Number:

Reporting of Continuously Monitored Emissions to Air for VOC mg/m3 at Emission Point A1 For the month of November 2020



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
Half-hourly average			Half-hourly average ELV	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20		
	Monthly maximum	46	Maximum Half-hourly average	6	2	1	1	1	0	0	10	1	1	2	1	0	46	2	Off	Off	Off	Off	0	0	0	1	0	0	1	0	4	1	2		
	Monthly mean	0	Mean Half-hourly average	1	1	1	0	0	0	0	1	0	0	0	0	0	2	1	Off	Off	Off	Off	0	0	0	0	0	0	0	0	0	0	0		
	Monthly minimum	0	Minimum Half-hourly average	0	1	0	0	0	0	0	0	0	0	0	0	0	0	1	Off	Off	Off	Off	0	0	0	0	0	0	0	0	0	0	0		
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	Sum of exceedances	2	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	Off	Off	Off	Off	0	0	0	0	0	0	0	0	0	0	0	
Daily average			Daily average ELV	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10		
	Monthly maximum	1	Daily average	N/A	N/A	1	0	0	0	0	N/A	0	0	0	0	N/A	N/A	N/A	Off	Off	Off	Off	0	N/A	0	0	0	0	0	0	0	0	0	0	
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y		
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed... *B. M. C.*

Date... 07.12.2020

(Authorised to sign as a representative of the Operator)