


Permit Reference Number : EPR / TP3836CT

Operator : Viridor

Installation: Beddington

Form Number: AIR 3 / 23/07/13 [A2]

Reporting of Continuously Monitored Emissions to Air for HCl mg/m3 at Emission Point A2 For the month of December 2022



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0	60.0
	Monthly maximum	76.6	Maximum Half-hourly average	2.4	3.7	4.6	2.8	8.7	13.2	5.5	17.1	12.4	6.3	4.2	6.5	7.8	8.1	7.0	8.6	17.2	9.2	12.1	9.3	10.5	8.8	76.6	9.5	10.1	9.3	9.6	11.0	11.6	9.0	8.7
	Monthly mean	4.3	Mean Half-hourly average	1.8	1.8	2.1	1.7	2.7	3.0	2.8	3.3	3.9	3.0	2.7	3.1	4.0	4.2	3.9	5.2	3.7	4.5	6.8	5.5	4.4	4.7	8.2	4.8	5.6	6.1	6.2	6.9	6.5	5.5	5.2
	Monthly minimum	0.7	Minimum Half-hourly average	1.4	1.4	1.6	1.4	1.2	1.5	1.6	1.4	0.7	1.2	1.4	1.1	1.4	1.3	1.5	2.3	0.9	1.8	3.3	2.6	1.8	1.6	2.1	2.9	2.3	2.4	3.9	3.6	3.4	2.0	2.7
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	1	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0
Daily average			Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
	Monthly maximum	8.2	Daily average	1.8	1.8	2.1	1.7	N/A	N/A	2.8	3.3	N/A	3.0	2.7	3.1	4.0	4.2	3.9	5.2	3.7	4.5	6.8	5.5	4.4	4.7	8.2	4.8	5.6	6.1	6.2	6.9	6.5	5.5	5.2
	No of invalid days	1	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed: *D. Anderson*

Date: *3.01.2023*

(Authorised to sign as a representative of the Operator)