


Permit Reference Number : EPR / TP3836CT

Operator : Viridor

Installation: Beddington

Form Number: AIR 5 / 23/07/13 [A2]

Reporting of Continuously Monitored Emissions to Air for SO₂ mg/m³ at Emission Point A2 For the month of March 2023



	Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average			Half-hourly average ELV	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0	200.0
	Monthly maximum	209.2	Maximum Half-hourly average	69.2	95.2	65.4	19.0	61.0	58.7	51.2	32.2	79.3	96.3	54.8	45.3	54.9	53.3	50.6	76.6	209.2	54.6	34.0	43.6	54.2	43.0	52.3	67.8	49.1	34.1	70.6	44.7	46.3	50.6	52.3
	Monthly mean	23.4	Mean Half-hourly average	33.5	34.6	20.7	43.1	42.7	26.6	13.8	8.2	45.2	26.9	25.4	18.5	20.9	21.6	19.2	22.5	24.1	23.4	17.7	17.8	17.4	17.3	18.2	21.1	25.8	20.7	17.7	16.5	20.6	21.9	22.7
	Monthly minimum	0.2	Minimum Half-hourly average	7.6	7.4	5.0	6.4	9.2	1.4	1.9	2.9	6.5	3.6	6.0	4.7	5.5	5.9	3.5	7.8	3.9	6.4	6.8	2.5	3.8	3.2	5.3	3.3	6.6	7.2	3.8	5.7	9.2	0.2	4.5
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	1	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average			Daily average ELV	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0
	Monthly maximum	43.1	Daily average	33.5	34.6	20.7	43.1	42.7	26.6	13.8	8.2	N/A	N/A	25.4	18.5	20.9	21.6	19.2	22.5	24.1	23.4	17.7	17.8	17.4	17.3	18.2	21.1	25.8	20.7	17.7	16.5	20.6	21.9	22.7
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed D. Anderson

Date 3.04.2023

(Authorised to sign as a representative of the Operator)